



ABN: 91 090 863 102 QBSA License Number: 1149818

Head Office: 174 Cavan Road, DRY CREEK, SOUTH AUSTRALIA, 5094

Phone: +61 8 8368 0263 ~ Fax: +61 8 8368 0203

QLD Office: 137 Benjamin Place, LYTTON QUEENSLAND, 4178

Phone: +61 7 3393 3355 ~ Fax: +61 7 3893 2120

FREECALL No: +61 1800 697 655

Website: [www.ozroll.com.au](http://www.ozroll.com.au)

Email: [sales@ozroll.com.au](mailto:sales@ozroll.com.au)

## Bushfire Tested AE Sentry Roller Shutter

To Whom It May Concern:

OzRoll Pty Ltd verifies that the SENTRY roller shutter supplied with AE401 extruded profile and installed in compliance with AS3959-2009 for windows and doors achieves a Bushfire Attack Level (BAL) 40.

The representative shutter was tested by the CSIRO to AS1530 Methods for fire tests on building materials, components and structures, Part 8.1-2007: Tests on elements of construction for buildings exposed to simulated bushfire attack - Radiant heat and small flaming sources.

SIGNED:  .....

On behalf of  
OzRoll Pty Ltd  
174 Cavan Rd,  
Dry Creek, South Australia 5094

DATE: 3 September 2015 .....